

# **FINAL PROTOCOL WORKSHEET for Ventilation Systems: DESIGN** **Supply- / Extract-Air Ventilation System with Heat Recovery**

## **Project**

Object: **Martin Residence**

Location Street, No.:

Location Postcode, Town:

Building Owner Name:

Building Owner Phone No.:

Year of Construction: **2020**

## **Ventilation Planning**

Company: **Sustainable Engineering Ltd**

Person in Charge: **Jason Quinn**

Street, No.:

Postcode, City:

Phone No.:

Date:

Signature:

## **Standard use or special requirements:**

**Dimensioning of the ventilation system according to standard use conditions**

## **2. Criteria for dimensioning the airflow volumes**

	reference values	number		resulting starting values
fresh air demand:				
per person:	<b>30</b> m³/h	<b>2</b>	=	<b>60.0</b> m³/h
extract air demand:				
kitchens:	<b>60</b> m³/h	<b>1</b>	=	<b>60.0</b> m³/h
bathrooms, utility rooms etc.:	<b>40</b> m³/h	<b>2</b>	=	<b>80.0</b> m³/h
WC, storage, etc.:	<b>20</b> m³/h	<b>1</b>	=	<b>20.0</b> m³/h
sum:				<b>160.0</b> m³/h
starting value nominal airflow (standard operation):				<b>60.0</b> m³/h

## **3. Distribution of the airflow volume flow rate**

Nr.	Room (each valve individually)	Area A m²	Clear Height h m	Room Volume A x h m³	Air Volume Flow Rate			Air Change Rate n 1/h	Type of Flow-Off Vent (door gap, grid in door leaf door frame, valve ...)
					V <sub>SU</sub> m³/h	V <sub>EX</sub> m³/h	V <sub>THROUGH</sub> m³/h		
1	Dining Room	12.88	2.50	32.2	10			0.31	
2	Master Bedroom	16.42	2.50	41.1	20			0.49	door gap
3	Bedroom 1	16.41	2.50	41.0	20			0.49	door gap
4	Bedroom 2	16.41	2.50	41.0	20			0.49	door gap
5	Living Room	21.51	2.50	53.8	18			0.33	door gap
6	Lobby	3.51	2.50	8.8			10	1.14	
7	Kitchen	12.88	2.50	32.2		30		0.93	
8	Bath 1	6.98	2.50	17.5		25		1.43	door gap
9	Bath 2	4.53	2.50	11.3		20		1.77	door gap
10	Laundry	5.00	2.50	12.5		17		1.36	door gap
11	Entry	5.23	2.50	13.1	4			0.31	door gap
12									
13									
14									
15									
16									
17									
18									
19									
20									
	sum:	121.76	---	304.40	92.0	92.0	---	0.30	

## **4. Adjusted airflow volumes, control range**

base ventilation:	<b>70.8</b>	m³/h	at least 30% below nominal airflow volume
nominal airflow volume:	<b>92.0</b>	m³/h	fresh air demand, at least 0.3-fold air change rate
peak ventilation:	<b>119.6</b>	m³/h	at least 30% above nominal airflow volume
ventilated area:	<b>121.8</b>	m²	
ventilated volume:	<b>304.4</b>	m³	
nominal airflow volume, sum:	<b>0.3</b>	1/h	

## **5. Efficiency requirements**

ventilation unit (manufacturer, product): **02ud-Zehnder ComfoAir Q350**

efficiency of heat recovery: **90** % (according to PHI testing method for the PHPP)

max. power consumption in nominal operating mode: **0.24** W (for fans and control)

## **6. Requirements for noise protection**

A-weighted noise pressure level of the unit in the living space: **25** dB(A)

A-weighted noise pressure level of the unit in the installation room: **35** dB(A)

## **7. Hygienic requirements**

fresh air filter:	F7
extract air filter:	G3

first link in the chain, if applicable before subsoil heat exchanger  
at least bathroom and laundry rooms; recommendation: all extract



SUSTAINABLE  
ENGINEERING LTD

**FINAL PROTOCOL WORKSHEET for Ventilation Systems: Initial Start-up**  
**Supply- / Extract-Air Ventilation System with Heat Recovery**

**Project**  
 Object: **Martin Residence**  
 Location Street, No.: **0**  
 Location Postcode, Town: **0**  
 Building Owner Name: **0**  
 Building Owner Phone No.: **0**  
 Year of Construction: **2020**

**Initial Start-up**  
 Company: **Sustainable Engineering Ltd**  
 Person in Charge: **Jason Quinn**  
 Street, No.:  
 Postcode, City:  
 Phone No.:  
 Date:

**Ventilation System**  
 Manufacturer:  
 Product Name:  
 Unit No.:  
 Control No.:

**1. Record of the air flow volumes, supply and extract air**

Nr.	Room	Design			Measurement 1		Measurement 2		Measurement 3		Type of Valve	Adjustment	Flow-Through	Noise	Filter Grade	Filter Clean?
		V <sub>SU</sub>	V <sub>EX</sub>	V <sub>THROUGH</sub>	V <sub>SU</sub>	V <sub>EX</sub>	V <sub>SU</sub>	V <sub>EX</sub>	V <sub>SU</sub>	V <sub>EX</sub>			V <sub>THROUGH</sub>			
		m³/h	m³/h	m³/h	m³/h	m³/h	m³/h	m³/h	m³/h	m³/h			m/s	dB(A)		
1	Dining Room	10														yes / no
2	Master Bedroom	20														yes / no
3	Bedroom 1	20														yes / no
4	Bedroom 2	20														yes / no
5	Living Room	18														yes / no
6	Lobby			10												yes / no
7	Kitchen		30													yes / no
8	Bath 1		25													yes / no
9	Bath 2		20													yes / no
10	Laundry		17													yes / no
11	Entry	4														yes / no
12																yes / no
13																yes / no
14																yes / no
15																yes / no
16																yes / no
17																yes / no
18																yes / no
19																yes / no
20																yes / no
	sum:	92.00	92.00	---									---	---	---	---

**2. Balance of airflow volume**

		Measurement 1		Measurement 2		Measurement 3		Disbalance	Type of Control	Adjustment	Noise	Filter Grade	Filter Clean?
		V <sub>AUL</sub>	V <sub>FOL</sub>	V <sub>AUL</sub>	V <sub>FOL</sub>	V <sub>AUL</sub>	V <sub>FOL</sub>				Measurement		
		m³/h	m³/h	m³/h	m³/h	m³/h	m³/h				dB(A)		
1	fresh air inlet			92	---		---	0%					yes / no
2	exhaust air outlet			---	92		---					-	yes / no

3. Initial start-up accomplished according to  
manufacturer's specifications:

yes / no

Signature: .....

